

Warren Community Water & Sewer Association, Inc.
17300 State Route 550
Marietta, Ohio 45750
(740) 373-8476

Required set up for installation of water service inside User's home:

- Line from Outside House
- Shut Off Valve
- Pressure Regulator
- Check Valve (Backflow Preventer)
- Inside Line

- Use at least 200 PSI pipe

Acknowledged by: _____ Date: _____

Service Address: _____

Service is considered active once your tap is installed. If there has been no usage during the billing cycle, a minimum bill will be assessed. Bills are issued monthly and due by the 15th.

Warren Community Water and Sewer Association Requirements for Installation of Water Line

Specifications:

1. All pipes must be PVC and must be rated at a minimum of 200 PSI.
2. Valves and valve boxes placed at both ends with air removal valves wherever necessary.
3. All fittings, bends and valves must be mechanically joined or clamped and must be supported by adequate blocking.
4. All pipe and fittings must be buried to a minimum depth of 30".
5. Sand is to be used both below and above to support pipe and fittings. In areas where rock is encountered, extreme care shall be used to ensure no large rocks are used during backfilling.
6. Mining pipe shall be used in areas where pipe is subjected to extreme stress and environmental issues such as follows:
 - a. Creeks
 - b. Road crossings
 - c. Slip areas
 - d. Areas containing rock
 - e. Areas determined by Warren Water
7. Creek and road crossings shall also be installed with a casing for future replacement and to prevent damage.
8. No other utilities electric, gas etc. may be installed in the ditch or within 5' of the water line installation.
9. Blue locating wire solid copper #12 AWG must be laid with pipe and extended up into the valve box for future locating of buried lines.
10. Water line warning tape must be buried 10" to 12" below ground surface during back filling.
11. Reclaiming to be performed by installing contractor.

Inspection and installation:

All work must be performed to the satisfaction of Warren Water and lines must be inspected before any backfilling.

Additional cost incurred by Warren Water for inspection after hours, weekends or holidays will be billed to the contractor.